





Microplastic occurrence and removal in unbranded refilled drinking water treatment systems: Implications for human exposure in Karawang, Indonesia

Gina Lova Sari^{1*} , Nadia Amanah¹, Zulfa Amala¹ , Setyo Budi Kurniawan² , Rizka Novembrianto³ , Mhd. Fauzi¹ , Andini Siti Rohmana¹, Nur Ridha Amethysia¹, Putri Sekti Cahyaningrum¹, Adinda Melianda Nainggolan¹

¹ Study Program of Environmental Engineering, Faculty of Engineering, Universitas Singaperbangsa Karawang, Jl. H.S. Ronggo Waluyo, Karawang, West Java 41361, Indonesia

² Research Centre for Environmental and Clean Technologies, National Research and Innovation Agency of Indonesia (BRIN), Jakarta Pusat 10340, Indonesia

³ Study Program of Environmental Engineering, Faculty of Engineering, Universitas Pembangunan Nasional “Veteran” Jawa Timur, Jl. Raya Rungkut Madya, Surabaya, East Java 60294, Indonesia

* Corresponding author’s e-mail: ginalovasari@gmail.com

ABSTRACT

It is undeniable that microplastics are found in many types of water, including drinking water. This study aims to investigate the presence of microplastics in one of the drinking water sources widely used by communities in Indonesia, namely unbranded refilled drinking water. The investigation was conducted at eight unbranded refilled drinking water depots in Karawang, West Java. A total of 2.00 L of raw and treated water samples were collected from each depot, prepared following the National Oceanic and Atmospheric Administration method, analyzed using an Olympus BX-41 microscope at tenfold magnification, and manually counted. The results showed that both raw and treated water from all unbranded refilled drinking water depots contained microplastics, with concentrations ranging from 15.50–42.00 particles/L and 6.50–17.50 particles/L, respectively. The dominant microplastics identified were fibers and fragments, with sizes ranging from 1.00–3.00 mm and less than 1.00 mm. Furthermore, the dominant color of the microplastics was black, indicating that the polymers were likely polyethylene, polypropylene, or polystyrene. This study provides novel evidence on microplastic contamination in unbranded refilled drinking water in Indonesia, offering baseline data for future environmental monitoring and risk assessment. These findings confirm that refilled drinking water consumed by communities in Indonesia may represent a potential pathway for the entry and accumulation of microplastics in the human body, posing significant health risks. Based on current findings, further research is required to improve water treatment performance and enhance public health protection.

Keywords: Karawang, microplastics, raw water, processed water, unbranded refilled drinking water.

INTRODUCTION

Plastic pollution in the aquatic environment has become a growing concern worldwide in recent years. Apart from causing pollution, plastic in the marine environment has also been proven to be one of the causes of microplastic abundance in waters through plastic destruction (Kooi et al., 2018; Lares et al., 2018; Liu et al., 202). Microplastics are plastic particles that measure less than 5.00 mm (Fauzi et al., 2024; Gambino et al., 2022;

Fauzi et al., 2023a). Due to their small size, microplastics can be easily ingested by aquatic organisms and enter the food chain, potentially posing risks to ecosystem and human health (Sari et al., 2021; Tagg et al., 2020). In addition, their persistence and widespread distribution in water bodies highlight the urgent need for comprehensive monitoring and effective mitigation strategies.

Many studies have reported that microplastics are found in freshwater, commonly used as a water

source for various community needs (Koelmans et al., 2019; Lambert and Wagner, 2018; Lenaker et al., 2019; Li et al., 2018; Wagner et al., 2014; Wang et al., 2017). This condition potentially contaminated treated water, such as tap water, as occurred in China, where 0.30 to 440.00 microplastic particles/L were found (Tong et al., 2020; Zhang et al., 2020). Tap water, which is used as raw water for drinking purposes, poses a significantly increased threat to human health, considering the similarity of microplastic properties with those of plastic, which are hard to decompose and toxic (Gambino et al., 2022; Kirstein et al., 2021). According to Carding et al., (2015); Gambino et al., (2022); and Lu et al., (2019), the effects were similar to oxidative stress, inflammatory and immunological responses, mitochondrial membrane disruption, gut microbiota, intestinal dysbiosis, etc.

Recently, microplastics have been found in bottled waters that are widely used by the public. Kirstein et al., (2021) reported that microplastics in bottled water in various countries were found to be $1.40\text{--}5.42 \times 10^7$ particles/L. Gambino et al., (2022) found that bottled water in Germany, Thailand, the USA, Italy, and Saudi Arabia was contaminated by 0.99–5864.00 microplastic particles/L. Furthermore, Aleksander-Kwaterczak et al., (2023) also reported that microplastics contaminated Polish bottled water as much as 87.00–188.00 particles/L. These findings indicate that bottled drinking water may represent a significant source of human exposure to microplastics. However, studies investigating microplastic contamination in alternative drinking water sources, particularly unbranded refilled drinking water, remain limited and require further investigation.

This condition shows the most concerning problem, considering the potential of long-term microplastic exposure to the entire community due to drinking water needs, which reach 2.50–3.00 L/person/day (Aleksander-Kwaterczak et al., 2023; Reed and Reed, 2013). In Indonesia, drinking water consumption is lower by 1.50–2.50 L/person/day (Harfika and Hanifah, 2021), where as much as 52.98% of the need is supplied with refillable drinking water from community storehouses, known as depots because of the affordable price. This high dependence on refilled drinking water may increase the potential risk of continuous microplastic exposure among the population.

To date, specific research on the MP abundance in refillable drinking water, especially in Indonesia, is current very limited. This research

aims to investigate the presence of microplastics in raw and processed water used for refilled drinking water depot in Karawang, Indonesia. This research is expected to describe the conditions for microplastics in drinking water, one of the exposure pathways into the human body. The findings of this study are expected to provide baseline data for future monitoring and risk assessment of microplastic contamination in drinking water. In addition, this research may support the development of more effective water treatment and management strategies to protect public health.

MATERIALS AND METHODS

Raw and processed water used for drinking water sampling was carried out at eight unbranded refilled drinking water depots in Karawang, Indonesia (Figure 1). A 2.00 L raw water sample was collected through a water tap before flowing into the refilled drinking water treatment unit (Christanto, 2023). Meanwhile, 19.00 L or 1.00 gallons of processed water for refilled drinking water are taken for each depot. The type of gallon used for sampling was polyethylene terephthalate (PET) as mentioned by Christanto (2023) and Putra (2022).

The National Oceanic and Atmospheric Administration prepared water samples to remove organic matter and separate microplastics before analysis (Aliabad et al., 2019; Masura et al., 2015). The separated microplastics were analyzed using a microscope Olympus BX – 41 with ten times magnification to group them into 3.00–5.00 mm, 1.00–3.00 mm, and less than 1.00 mm. These particles were manually counted to determine their abundance in each sample using the formula:

$$A_{MP} = \frac{N_{MP}}{V_s} \quad (1)$$

where: A_{MP} – microplastics abundance (particles/L), N_{MP} – number of identified microplastics in sample (particles), V_s – volume of analyzed sample (L).

Furthermore, the physical properties of these microplastics, in shape and color, were also determined. The particles are categorized into fibers, films, foams, and fragments based on shape (Fauzi et al., 2023b). Meanwhile, the colors are black, yellow, transparent, white, red, blue, and green (Aliabad et al., 2019; Lin et al., 2018; Masura et al., 2015; Peng et al., 2017). All analyses in the current research were conducted in duplicate.




Figure 1. Map of raw and processed water sampling location in Karawang

The type of microplastic polymer found was also determined to identify its source. The analysis was performed using ATR-FTIR (Basri et al., 2021), Thermo Scientific Nicolet iS10 ATR-FTIR at a wavelength of 4000–650 cm⁻¹.

RESULTS AND DISCUSSION

The abundance of microplastics on raw water for unbranded refilled drinking water

Microplastics were detected in raw water samples, with a total abundance ranging from 15.50 to 42.00 particles/L (Table 1). The raw water used in the unbranded refilled drinking water process

in current research comes from several springs (Wanayasa and Mount Salak) and groundwater in West Java. It is piped and stored in a water tower before being processed by the depots.

The presence of microplastics in raw water from springs for Depot-1 to Depot-5 is significantly influenced by anthropogenic activities. Still referring to Table 1, the abundance of MP from Depot-1 was significantly higher as compared to other depot sourced its water from spring water, while Depot-6 showed significantly higher among other depot sourced its water from groundwater. According to Yanuar et al., (2024) and Nesterovschi et al., (2023), the discharge of wastewater from domestic activities such as showers and

Table 1. The total abundance of microplastics in raw water

Depot	Source of raw water	The abundance of microplastic (particles/L)
1	Springs	42.00*
2		36.00
3		25.00
4		24.50
5		18.50
6	Groundwater	19.00*
7		16.50
8		15.50

Note: an asterisk symbol (*) indicates the highest significant abundance of MP in the same source of raw water.

washing near the springs is one of the significant contributors to microplastic pollution. It is further supported by his research, which found an abundance of microplastics ranging from 0.20–0.30 particles/L at six springs in Batu City, East Java (Yanuar et al., 2024). This finding is particularly relevant to the microplastic contamination pathways, where wastewater discharge is one of the primary routes for microplastic transfer into water (Van Emmerik et al., 2019).

Moreover, Nesterovschi et al., (2023) also found that microplastics with an average of 0.034–0.06 particles/L at three karst springs in Romania. This may be due to the fragmentation of plastic waste around the karst spring location, such as used bottles and plastic packaging. This assumption is also quite relevant, considering that secondary sources of microplastics come from fragmentation and mechanical destruction of plastic waste in the environment (Galafassi et al., 2019; Gambino et al., 2022; Nesterovschi et al., 2023). As Gambino et al., (2022) explained, due to their petite size and lightweight, fragmented plastics such as microplastics may be transported by wind or surface runoff from contaminated soil to spring

The abundance of microplastics for raw water derived from groundwater in Depot-6 to Depot-8 was 15.50–19.00 particles/L. Similar microplastic contamination was also found in groundwater in India, Germany, and Australia as much as 10.10 particles/L (Selvam et al., 2021); 0.01 particles/L (Mintenig et al., 2019); and 38.00 ± 8.00 particles/L (Samandra et al., 2022), respectively. Similar to the sources of microplastic contamination in springs, the discharge of domestic wastewater and fragmented plastics also causes microplastics in groundwater.

Microplastics could enter the soil through porosity, permeability, and the activity of living organisms (Guo et al., 2020; Monkul and Özhan, 2021). Soil pores and permeability can facilitate the vertical and horizontal movement of fragmented microplastics along with water infiltration (Van Emmerik et al., 2019). Meanwhile, the tiny size of microplastics is also potentially moved by the excretion and movement of soil-living organisms because they are attached to their bodies.

Referring to the distribution of domestic wastewater in Indonesia, which combines grey water and black water in septic tanks, it is might be one of the factors in the presence of microplastics in groundwater through water infiltration (Samandra et al.,

2022). It is reinforced by research by (Panno et al., 2019) which found a correlation between the abundance of microplastics in septic tank wastewater and groundwater in the United States. (Huang et al., 2021; Selvam et al., 2021; Waryati et al., 2023) also supported that wells close to residential areas, especially domestic wastewater discharge, have a higher potential for microplastic contamination up to the hyporheic zone and groundwater through rock fissures and aquifer fractures. These factors encourage the movement of microplastics in the soil, which potentially enter the groundwater system (Ren et al., 2021).

The findings of dominance shapes supported the alleged source of microplastic contamination in all samples were fibers and fragments were significantly higher than other shapes, with an average of 14.06 particles/L and 8.13 particles/L, respectively (Figure 2). According to (Yanuar et al., 2024), fibers come from wash wastewater containing ropes or threads from fabrics/textiles and plastics. The fibers found in eight raw water samples were dominated by 1.00–3.00 mm and less than 1.00 mm of microplastics, with an average of 6.88 particles/L and 3.88 particles/L, respectively. Meanwhile, the fragments in all samples most likely emerged from fragmented plastic waste. The dominant fragments found were less than 1.00 mm of 7.00 particles/L.

The dominance of fibers and fragments in the current study indicates the presence of other sources of microplastic contamination as plastic particles released from pipes and reservoir utilization (Angelina, 2023; Dalmau-Soler et al., 2021; Koelmans et al., 2019; Samandra et al., 2022). Figure 2 shows that 1–3 mm MP significantly dominated the films and fibers, while a size <1 mm significantly dominated the fragments. Plastic pipes in the water distribution might cause abrasion due to mechanical pressure that drives the release of microplastic particles into the water (Angelina, 2023; Dalmau-Soler et al., 2021). It is supported by Vega-Herrera et al., (2022), who reported that polymer microplastics in the form of polyethylene (PE), polypropylene (PP), polyisoprene (PI), polybutadiene (PMMA), polystyrene (PS), polyamide (PA), polyvinyl chloride (PVC), and PET were found in household tap water that uses plastic pipes in the distribution process. In addition, the microplastics released also increased with the age of the pipes and reservoirs (Mukotaka et al., 2021; Samandra et al., 2022; Shruti et al., 2020; Tong




Figure 2. Shape and size of microplastics in raw water samples. An asterisk symbol (*) indicates the highest significant abundance of MP size from the same shape

et al., 2020; Venecia, 2023; Waryati et al., 2023). This information is related to the current conditions in the current study, where the pipe and reservoir materials used for the water distribution and storage before being processed by the depot are PVC and PE, respectively.

The abundance of microplastics in processed water for unbranded refilled drinking water

Microplastics in processed water for unbranded refilled drinking water originating from raw water (as investigated in the previous sub-section) showed a lower abundance, ranging from 6.50 to 17.50 particles/L (Table 2). These results show similarities with several previous microplastic

studies in Indonesia, which found microplastics in refilled drinking water as many as 13.00–135.30 particles/L (Saraswati, 2023); 548.00±110.03–1134.33±144.14 particles/L (Angelina, 2023); 268.11±28.90 particles/L (Christanto, 2023); 139.17–190.30 particles/L (Putra, 2022); 0.10–1.10 particles/L (Syarif et al., 2021). It indicates the potential risks to public health and should be a significant concern.

Table 2 shows that the water treatment used for unbranded refilled drinking water, consisting of filtration and sterilization, can remove microplastics as much as 6.00–32.50 particles/L. Filtration in the water treatment process using GAC, SF, and RO, reported by (Gao et al., 2022), can remove the abundance of microplastics in refilled

Table 2. The abundance of microplastics on processed water

Depot	The abundance of microplastic (particles/L)	Type of water treatment		Removal (particles/L)
		Filtration	Sterilization	
1	9.50	Granular activated carbon (GAC) and sand filter (SF)	Ultraviolet	32.50
2	17.50	GAC and SF	Ultraviolet	18.50
3	17.50	GAC and SF	Ozonation and ultraviolet	7.50
4	9.00	GAC and SF	Ozonation and ultraviolet	15.50
5	8.50	GAC and SF	Ultraviolet	10.00
6	6.50	GAC, SF, and reverse osmosis (RO)	-	12.50
7	9.00	GAC, SF, and RO	-	7.50
8	9.50	GAC, SF, and RO	-	6.00

drinking water. However, the differences in the microplastic effectiveness removal found in this study may be influenced by the pore size of the filter used, where GAC, SF, and RO measuring 0.20–0.50 mm and 1×10^{-6} mm, respectively (Dalmau-Soler et al., 2021).

Following filter pore size, using a filter combination may increase the effectiveness of microplastic removal (Mintinig et al., 2019; Pivokonsky et al., 2018). As found in current research, where the highest effectiveness of microplastic removal was found in Depot-1 (32.50 particles/L), Depot-2 (18.50 particles/L), and Depot-4 (15.50 particles/L), which used a combination of GAC and SF. Furthermore, Depot-6, Depot-7, and Depot-8 combined GAC, SF, and RO showed a lower microplastic removal of 6.00–12.50 particles/L. The condition is due to the low abundance of microplastics in raw water before processing, dominated by sizes less than 1.00 mm, which the treatment can only partially remove.

Another factor that also affects the effectiveness of removal by the filter is the shape and size of the microplastic in the water. Figures 2 and 3 show that the microplastics (1.00–5.00 mm) removed in current research were dominated by fibers and films as much as 15.13 particles/L and 3.75 particles/L, respectively. Meanwhile, fragments are the most removed for microplastics with a size of less than 1.00 mm. Fragments and films that the filter can remove are illustrated in Figures 4b and 4c. Furthermore, Figures 2 and

3 show no difference in the microplastics with a size of less than 1.00 mm from the fiber. Due to their shape resembling a rope, tiny size, and diameter, fiber can pass the pores of the filter and escape the water treatment process (De Falco et al., 2019). The illustration of fiber can be seen in Figure 4a.

The colour of microplastics in raw and processed water for unbranded refilled drinking water

Figure 4 shows a similar dominance of microplastic colors between raw and processed water (Figure 5). The highly significant abundant microplastic colors in raw water are black, red, and transparent, with an abundance of 10.88 particles/L (44.16%), 4.00 particles/L (16.24%), 3.44 particles/L (13.96%). Meanwhile, the dominant colors of microplastics found in processed water were black, blue, transparent, and yellow, with an abundance of 3.56 particles/L (36.08%), 2.19 particles/L (22.15%), 1.50 particles/L (15.19%); and 1.50 particles/L (15.19%). This finding was similar to An et al., (2022) and Yanuar et al., (2024), who reported that black was the dominant color of microplastics in their study area, reaching 39.01% and 28.40%, respectively.

Zhang et al., (2020) and Murphy et al., (2016) stated that the color of microplastics can indicate the source of the contaminating microplastics. Supriyo and Noviana (2023) also informed that




Figure 3. Shape and size of microplastics in processed water samples. An asterisk symbol (*) indicates the highest significant abundance of MP size from the same shape




Figure 4. The shape of microplastic: a) fiber; b) fragment; c) film




Figure 5. The colour of microplastics. An asterisk symbol (*) indicates the highest significant abundance of MP color from the water source

the various colors may be related to the chemical composition of the microplastics in the water. The black color of microplastics indicates that it is made of PP or PS polymers (Laksono et al., 2021). Dark colors can detect low-density PE polymers early (Kapo et al., 2020). In addition, microplastics with dense and bright colors indicate that microplastics have no discoloration and become transparent (Febriani et al., 2020; Kapo et al., 2020). Transparent colors are usually found in film-shaped microplastics, which are assumed from the original color of plastic packaging made by PP and PE polymers (Makhdoumi et al., 2021). Furthermore, green, blue, yellow, and red microplastics are likely from the original color of the plastic (Romaskila et al., 2023).

PP, PS, and PE are frequently plastic polymers in water that use plastic pipes for their supply system or storage tank. As found by Feld et al., (2021); Mintenig et al., (2019); Mukotaka

et al., (2021); and Pittroff et al., (2021) that PP, PS, and PE are dominant polymers in tap water, which are processed from groundwater; this is reasonably related to the alleged polymers contained in microplastics found in the current study.

Potential risk to public health and further research

These results are a stark reminder of the potentially severe health risks microplastics pose in drinking water. Given that the average human consumes 1.50–2.50 L of water daily, ingesting a significant number of microplastic particles is a concerning reality. This continuous exposure could lead to profound health implications if not promptly addressed.

Despite microplastics' effects and toxic consequences in vivo on the human body, they are still unclear. To date, the toxicity of microplastics

is frequently associated with their constituent polymer compounds, additives added during the manufacturing process, and their impact on humans. Additives used in plastic manufacturing, such as plasticizers, stabilizers, lubricants, dyes, and pigments, etc., may cause oxidative stress, lipid metabolism disorders, gut microbiota, mitochondrial membrane disruption, and even cancer in many organisms, including humans (Carding et al., 2015; Gambino et al., 2022; Hermabessiere et al., 2017). In addition, the ability of microplastics to adsorb and concentrate bacteria and viruses can potentially increase systemic inflammation, which might cause anemia in humans (Carding et al., 2015; Naik et al., 2019; Prendergast et al., 2015; Sari et al., 2021). However, the possible effects of microplastics still depend on the time and intensity of exposure and the immunological responses of human antibodies.

The translocation of microplastics in the human body occurs through the lymphatic system and blood circulation, which is influenced by their size and shape. The tiny fibers make their movement more straightforward across epithelial and endothelial cells into the circulatory system (Gray and Weinstein, 2017; Oberdörster et al., 2005). As reported by Leslie et al., (2022) that, as many as 1.60 µg/ml microplastics in human blood are identified as PET, PE, and PS. Meanwhile, larger microplastics can be excreted through the human excretory system, as found by N. Zhang et al., (2021), there are 1.00–36.00 particles of microplastics/g human feces in the size of 20.00 to 800.00 µm. Moreover, Schwabl et al., (2019) also found 20.00 particles of microplastics in every ten grams of human feces with a size of 50.00–500 µm.

Referring to this, the current study's processed water findings were dominated by fibers measuring less than 1.00 mm, which have great potential for translocation and accumulation in the human circulatory system. The current study has underscored the pressing need for further research to understand these factors and improve water treatment processes fully, highlighting the urgency and importance of this topic to the sustainability of human health.

CONCLUSIONS

The results showed that raw and processed water used in eight unbranded refilled drinking

water depots in Karawang, West Java, contained microplastics with a total abundance ranging from 15.50–42.00 particles/L and 6.50–17.50 particles/L, respectively. Microplastic in raw water was dominated by fiber and fragments of 1.00–3.00 mm and less than 1.00 mm, as much as 13.75 particles/L and 14.00 particles/L, respectively. Meanwhile, the abundance of microplastics in processed water was dominated by fiber and fragments of less than 1.00 mm, as much as 7.13 particles/L and 4.2 particles/L. The abundance of microplastics in processed water showed that the treatment used in each depot removed microplastics with a size of 1.00–5.00 mm. Nevertheless, the presence of microplastics in processed water should increase the government's and the public's awareness of water utilization. More importantly, further studies are crucial to enhance water treatment technologies and remove microplastics in unbranded refilled drinking water.

Acknowledgments

The authors gratefully acknowledge the financial support provided by the Ministry of Higher Education, Science, and Technology of the Republic of Indonesia through Research Grant No. 108/C3/DT.05.00/PL/2025.

REFERENCES

1. Aleksander-Kwaterczak, U., Gaj, D., Stelmach, A., Wróbel, T. P. (2023). Investigating the Content of Microplastics and other Extraneous Particles in Polish Bottled Water. *Geology, Geophysics and Environment*, 49(4), 335–353. <https://doi.org/10.7494/geol.2023.49.4.335>
2. Aliabad, M. K., Nassiri, M., Kor, K. (2019). Microplastics in the surface seawaters of Chabahar Bay, Gulf of Oman (Makran Coasts). *Marine Pollution Bulletin*, 143, 125–133. <https://doi.org/10.1016/j.marpolbul.2019.04.037>
3. An, X., Li, W., Lan, J., Adnan, M. (2022). Preliminary study on the distribution, source, and ecological risk of typical microplastics in Karst Groundwater in Guizhou Province, China. *International Journal of Environmental Research and Public Health*, 19(22). <https://doi.org/10.3390/ijerph192214751>
4. Angelina, J. (2023). *Microplastic Detection in Drinking Water from Refill Stations in South Semarang Sub-District*. Universitas Katolik Soegijapranata Semarang.

5. Basri, S. K., Syaputra, E. M., Handayani, S. (2021). Microplastic pollution in waters and its impact on health and environment in Indonesia: A review. *Journal of Public Health for Tropical and Coastal Region*, 4(2).
6. Carding, S., Verbeke, K., Vipond, D. T., Corfe, B. M., Owen, L. J. (2015). Dysbiosis of the gut microbiota in disease. *Microbial Ecology in Health & Disease*, 26, 1–9. <https://doi.org/10.3402/mehd.v26.26191>
7. Christanto, M. A. (2023). *Microplastics Detection in Drinking Water from Refill Stations in Central Semarang Sub-District*. Universitas Katolik Soegijapranata.
8. Dalmau-Soler, J., Ballesteros-Cano, R., Boleda, M. R., Paraira, M., Ferrer, N., Lacorte, S. (2021). Microplastics from headwaters to tap water: Occurrence and removal in a drinking water treatment plant in Barcelona Metropolitan Area (Catalonia, NE Spain). *Environmental Science and Pollution Research*, 28(42), 59462–59472. <https://doi.org/10.1007/s11356-021-13220-1>
9. De Falco, F., Di Pace, E., Cocca, M., Avella, M. (2019). The contribution of washing processes of synthetic clothes to microplastic pollution. *Scientific Reports*, 9(1), 1–11. <https://doi.org/10.1038/s41598-019-43023-x>
10. Fauzi, M., Soewondo, P., Handajani, M., Tedjakusuma, T., Nur, A., Qadafi, M., (2024). Characteristics and removal of microplastics in urban domestic WWTP system: A case study in Bandung city, Indonesia. *Case Stud. Chem. Environ. Eng.* 10, 100999. <https://doi.org/10.1016/J.CSCEE.2024.100999>
11. Fauzi, M., Soewondo, P., Darnas, Y., Handajani, M., Tedjakusuma, T., Nizar, M., Muna, C.R., Nur, A. (2023a). Microplastics abundance in domestic wastewater as a pollutant source for the Daroy River, Indonesia, *J. Water Land Dev.* 59, 118–125, <https://doi.org/10.24425/JWLD.2023.147236>
12. Fauzi, M., Darnas, Y., Muna, C.R., Nizar, M. (2023b). Distribution of microplastics in domestic wastewater and microplastics removal potential in wastewater treatment plants, *J. Ecol. Eng.* 24, 79–86, <https://doi.org/10.12911/22998993/172293>
13. Febriani, I. S., Amin, B., Fauzi, M. (2020). Distribution of microplastic in water of Bengkalis Island of Riau Province (in Bahasa). *Depik*, 9(3), 386–392. <https://doi.org/10.13170/depik.9.3.17387>
14. Feld, L., Da Silva, V. H., Murphy, F., Hartmann, N. B., Strand, J. (2021). A study of microplastic particles in Danish tap water. *Water (Switzerland)*, 13(15). <https://doi.org/10.3390/w13152097>
15. Galafassi, S., Nizzetto, L., Volta, P. (2019). Plastic sources: A survey across scientific and grey literature for their inventory and relative contribution to microplastics pollution in natural environments, with an emphasis on surface water. *Science of the Total Environment*, 693, 133499. <https://doi.org/10.1016/j.scitotenv.2019.07.305>
16. Gambino, I., Bagordo, F., Grassi, T., Panico, A., De Donno, A. (2022). Occurrence of microplastics in tap and bottled water: Current knowledge. *International Journal of Environmental Research and Public Health*, 19(9). <https://doi.org/10.3390/ijerph19095283>
17. Gao, W., Zhang, Y., Mo, A., Jiang, J., Liang, Y., Cao, X., He, D. (2022). Removal of microplastics in water: technology progress and green strategies. *Green Analytical Chemistry*, 3(October), 100042. <https://doi.org/10.1016/j.greeac.2022.100042>
18. Gray, A. D., Weinstein, J. E. (2017). Size- and shape-dependent effects of microplastic particles on adult Daggerblade grass shrimp (*Palaemonetes Pugio*). *Environmental Toxicology and Chemistry*, 36(11), 3074–3080. <https://doi.org/10.1002/etc.3881>
19. Guo, J. J., Huang, X. P., Xiang, L., Wang, Y. Z., Li, Y. W., Li, H., Cai, Q. Y., Mo, C. H., Wong, M. H. (2020). Source, migration and toxicology of microplastics in soil. *Environment International*, 137(September 2019), 105263. <https://doi.org/10.1016/j.envint.2019.105263>
20. Harfika, M., Hanifah, A. (2021). Bacteriological quality analysis (MPN E-Coli) of refill drinking water depots in Johar Baru District. *Jurnal Untuk Masyarakat Sehat (JUKMAS)*, 5(2), 151–160. <https://doi.org/10.52643/jukmas.v5i2.1383>
21. Huang, J., Chen, H., Zheng, Y., Yang, Y., Zhang, Y., Gao, B. (2021). microplastic pollution in soils and groundwater: Characteristics, analytical methods and impacts. *Chemical Engineering Journal*, 425(xxxx), 131870. <https://doi.org/10.1016/j.cej.2021.131870>
22. Kapo, F. A., Toruan, L. N. L., Paulus, C. A. (2020). The types and abundance of microplastics in surface water at Kupang Bay (in Bahasa). *Jurnal Bahari Papadak*, 1(1), 10–21.
23. Kirstein, I. V., Gomiero, A., Vollertsen, J. (2021). Microplastic pollution in drinking water. *Current Opinion in Toxicology*, 28, 70–75. <https://doi.org/10.1016/j.cotox.2021.09.003>
24. Koelmans, A. A., Mohamed Nor, N. H., Hermsen, E., Kooi, M., Mintenig, S. M., De France, J. (2019). Microplastics in freshwaters and drinking water: Critical review and assessment of data quality. In *Water Research* 155, 410–422. Elsevier Ltd. <https://doi.org/10.1016/j.watres.2019.02.054>
25. Kooi, M., Besseling, E., Kroeze, C., Van Wezel, A. P., Koelmans, A. A. (2018). Modeling the fate and transport of plastic debris in freshwaters: Review and Guidance. In *Handbook of Environmental Chemistry* 58, 125–152. Springer Verlag. https://doi.org/10.1007/978-3-319-61615-5_7

26. Laksono, O. B., Suprijanto, J., Ridlo, A. (2021). Microplastic content in sediment in Bandengan Waters, Kendal Regency. *Journal of Marine Research*, 10(2), 158–164. <https://doi.org/10.14710/jmr.v10i2.29032>
27. Lambert, S., Wagner, M. (2018). Microplastics are contaminants of emerging concern in freshwater environments: An overview. In *Handbook of Environmental Chemistry* 58, 1–23. Springer Verlag. https://doi.org/10.1007/978-3-319-61615-5_1
28. Lares, M., Ncibi, M. C., Sillanpää, M., Sillanpää, M. (2018). Occurrence, identification and removal of microplastic particles and fibers in conventional activated sludge process and advanced MBR technology. *Water Research*, 133, 236–246. <https://doi.org/10.1016/j.watres.2018.01.049>
29. Lenaker, P. L., Baldwin, A. K., Corsi, S. R., Mason, S. A., Reneau, P. C., Scott, J. W. (2019). Vertical distribution of microplastics in the water column and surficial sediment from the Milwaukee River Basin to Lake Michigan. *Environmental Science and Technology*, 53(21), 12227–12237. <https://doi.org/10.1021/acs.est.9b03850>
30. Leslie, H. A., van Velzen, M. J. M., Brandsma, S. H., Vethaak, A. D., Garcia-Vallejo, J. J., Lamoree, M. H. (2022). Discovery and quantification of plastic particle pollution in human blood. *Environment International*, 163(December 2021), 107199. <https://doi.org/10.1016/j.envint.2022.107199>
31. Li, J., Liu, H., Paul Chen, J. (2018). Microplastics in freshwater systems: A review on occurrence, environmental effects, and methods for microplastics detection. *Water Research*, 137, 362–374. <https://doi.org/10.1016/j.watres.2017.12.056>
32. Lin, L., Zuo, L. Z., Peng, J. P., Cai, L. Q., Fok, L., Yan, Y., Li, H. X., Xu, X. R. (2018). Occurrence and distribution of microplastics in an Urban River: A case study in the Pearl River along Guangzhou City, China. *Science of the Total Environment*, 644, 375–381. <https://doi.org/10.1016/j.scitotenv.2018.06.327>
33. Liu, W., Zhang, J., Liu, H., Guo, X., Zhang, X., Yao, X., Cao, Z., Zhang, T. (2021). A review of the removal of microplastics in global wastewater treatment plants: Characteristics and mechanisms. In *Environment International* 146. Elsevier Ltd. <https://doi.org/10.1016/j.envint.2020.106277>
34. Lu, L., Luo, T., Zhao, Y., Cai, C., Fu, Z., Jin, Y. (2019). Interaction between microplastics and microorganism as well as Gut Microbiota: A consideration on environmental animal and human health. *Science of the Total Environment*, 667, 94–100. <https://doi.org/10.1016/j.scitotenv.2019.02.380>
35. Makhdomi, P., Amin, A. A., Karimi, H., Pirsahab, M., Kim, H., Hossini, H. (2021). Occurrence of microplastic particles in the most popular Iranian bottled mineral water brands and an assessment of human exposure. *Journal of Water Process Engineering*, 39(September), 101708. <https://doi.org/10.1016/j.jwpe.2020.101708>
36. Masura, J., Baker, J., Foster, G., Arthur, C. (2015). *Laboratory Methods for the Analysis of Microplastics in the Marine Environment: Recommendations for quantifying synthetic particles in waters and sediments*.
37. Mintenig, S. M., Löder, M. G. J., Primpke, S., Gerdt, G. (2019). Low numbers of microplastics detected in drinking water from ground water sources. *Science of the Total Environment*, 648, 631–635. <https://doi.org/10.1016/j.scitotenv.2018.08.178>
38. Monkul, M. M., Özhan, H. O. (2021). Microplastic contamination in soils: A review from geotechnical engineering view. *Polymers*, 13(23). <https://doi.org/10.3390/polym13234129>
39. Mukotaka, A., Kataoka, T., Nihei, Y. (2021). Rapid analytical method for characterization and quantification of microplastics in tap water using a Fourier-Transform infrared microscope. *Science of the Total Environment*, 790, 148231. <https://doi.org/10.1016/j.scitotenv.2021.148231>
40. Murphy, F., Ewins, C., Carbonnier, F., Quinn, B. (2016). Wastewater treatment works (WwTW) as a source of microplastics in the aquatic environment. *Environmental Science and Technology*, 50(11), 5800–5808. <https://doi.org/10.1021/acs.est.5b05416>
41. Nesterovschi, I., Marica, I., Andrea Levei, E., Bogdan Angyus, S., Kenez, M., Teodora Moldovan, O., Cîntă Pinzaru, S. (2023). Subterranean transport of microplastics as evidenced in karst springs and their characterization using Raman spectroscopy. *Spectrochimica Acta - Part A: Molecular and Biomolecular Spectroscopy*, 298(April). <https://doi.org/10.1016/j.saa.2023.122811>
42. Oberdörster, G., Oberdörster, E., Oberdörster, J. (2005). Nanotoxicology: An emerging discipline evolving from studies of ultrafine particles. *Environmental Health Perspectives*, 113(7), 823–839. <https://doi.org/10.1289/ehp.7339>
43. Panno, S. V., Kelly, W. R., Scott, J., Zheng, W., McNeish, R. E., Holm, N., Hoellein, T. J., Baranski, E. L. (2019). Microplastic contamination in Karst groundwater systems. *Groundwater*, 57(2), 189–196. <https://doi.org/10.1111/gwat.12862>
44. Peng, G., Zhu, B., Yang, D., Su, L., Shi, H., Li, D. (2017). Microplastics in Sediments of the Changjiang Estuary, China. *Environmental Pollution*, 225, 283–290. <https://doi.org/10.1016/j.envpol.2016.12.064>
45. Pittroff, M., Müller, Y. K., Witzig, C. S., Scheurer, M., Storck, F. R., Zumbülte, N. (2021). Microplastic analysis in drinking water based on fractionated filtration sampling and Raman microspectroscopy. *Environmental Science and Pollution Research*,

- 28(42), 59439–59451. <https://doi.org/10.1007/s11356-021-12467-y>
46. Pivokonsky, M., Cermakova, L., Novotna, K., Peer, P., Cajthaml, T., Janda, V. (2018). Occurrence of microplastics in raw and treated drinking water. *Science of the Total Environment*, 643, 1644–1651. <https://doi.org/10.1016/j.scitotenv.2018.08.102>
47. Putra, Y. A. S. (2022). Microplastics detection in refillable drinking water in Tembalang Sub-District, Semarang City and Estimation of their exposure to the human body. In *Skripsi. Program Sarjana Teknologi Pangan. Universitas Katolik Soegijapranata Semarang*. Universitas Katolik Soegijapranata.
48. Reed, B. J., Reed, R. (2013). How much water is needed in emergencies. In *Technical Notes on Drinking-Water, Sanitation and Hygiene in Emergencies* (Issue July).
49. Ren, Z., Gui, X., Xu, X., Zhao, L., Qiu, H., Cao, X. (2021). Microplastics in the soil-groundwater environment: aging, migration, and co-transport of contaminants – A critical review. *Journal of Hazardous Materials*, 419(March), 126455. <https://doi.org/10.1016/j.jhazmat.2021.126455>
50. Romaskila, U., Widiastuti, E. L., Susanto, G. N., Damai, A. A., Juliasih, N. L. G. R. (2023). Characteristics, color and size of microplastics founded in water and green mussel at Pasar Island, Lampung (in Bahasa). *Journal of Tropical Marine Science*, 6(2), 147–154. <https://doi.org/10.33019/jour.trop.mar.sci.v6i2.4236>
51. Samandra, S., Johnston, J. M., Jaeger, J. E., Symons, B., Xie, S., Currell, M., Ellis, A. V., Clarke, B. O. (2022). Microplastic contamination of an unconfined groundwater aquifer in Victoria, Australia. *Science of the Total Environment*, 802, 149727. <https://doi.org/10.1016/j.scitotenv.2021.149727>
52. Saraswati, M. K. (2023). *Detection of The Presence of Microplastics in Refillable Galloon Bottled Drinking Water in The Bendan and Karangrejo Sub-Districts*. Universitas Katolik Soegijapranata.
53. Sari, G. L., Kasasiah, A., Utami, M. R., Trihadiningrum, Y. (2021). Microplastics contamination in the aquatic environment of Indonesia: A comprehensive review. *Journal of Ecological Engineering*, 22(10), 127–140. <https://doi.org/10.12911/22998993/142118>
54. Schwabl, P., Koppel, S., Konigshofer, P., Bucsics, T., Trauner, M., Reiberger, T., Liebmann, B. (2019). Detection of various microplastics in human stool: A prospective case series. *Annals of Internal Medicine*, 171(7), 453–457. <https://doi.org/10.7326/M19-0618>
55. Selvam, S., Jesuraja, K., Venkatramanan, S., Roy, P. D., Jeyanthi Kumari, V. (2021). Hazardous microplastic characteristics and its role as a vector of heavy metal in groundwater and surface water of Coastal South India. *Journal of Hazardous Materials*, 402(August 2020), 123786. <https://doi.org/10.1016/j.jhazmat.2020.123786>
56. Shruti, V. C., Pérez-Guevara, F., Kutralam-Muniasamy, G. (2020). Metro station free drinking water fountain - A potential “Microplastics Hotspot” for human consumption. *Environmental Pollution*, 261. <https://doi.org/10.1016/j.envpol.2020.114227>
57. Syarif, M., Daud, A., Natsir, Muh. F. (2021). Identification of the existence and form of microplastic in refilled drinking water in Tamangapa Village, Makassar City. *Hasanuddin Journal of Public Health*, 2(3), 346–354. <https://doi.org/10.30597/hjph.v2i3.11971>
58. Tagg, A. S., Sapp, M., Harrison, J. P., Sinclair, C. J., Bradley, E., Ju-Nam, Y., Ojeda, J. J. (2020). Microplastic monitoring at different stages in a wastewater treatment plant using reflectance micro-FTIR imaging. *Frontiers in Environmental Science*, 8. <https://doi.org/10.3389/fenvs.2020.00145>
59. Tong, H., Jiang, Q., Hu, X., Zhong, X. (2020). Occurrence and identification of microplastics in tap water from China. *Chemosphere*, 252. <https://doi.org/10.1016/j.chemosphere.2020.126493>
60. Van Emmerik, T., Tramoy, R., van Calcar, C., Alligant, S., Treilles, R., Tassin, B., Gasperi, J. (2019). Seine plastic debris transport tenfolded during increased river discharge. *Frontiers in Marine Science*, 6(October), 1–7. <https://doi.org/10.3389/fmars.2019.00642>
61. Vega-Herrera, A., Llorca, M., Borrell-Diaz, X., Redondo-Hasselerharm, P. E., Abad, E., Villanueva, C. M., Farré, M. (2022). Polymers of micro(Nano) plastic in household tap water of the Barcelona Metropolitan Area. *Water Research*, 220. <https://doi.org/10.1016/j.watres.2022.118645>
62. Venecia, J. A. (2023). *Microplastic Detection of Bottle Water from Water Refill Depots in Pedurungan Sub-District Semarang City*. Unniversitas Katolik Soegijapranata Semarang.
63. Wagner, M., Scherer, C., Alvarez-Muñoz, D., Brennholt, N., Bourrain, X., Buchinger, S., Fries, E., Grosbois, C., Klasmeier, J., Marti, T., Rodriguez-Mozaz, S., Urbatzka, R., Vethaak, A. D., Winther-Nielsen, M., Reifferscheid, G. (2014). Microplastics in freshwater ecosystems: what we know and what we need to know. *Environmental Sciences Europe*, 26(1), 1–9. <https://doi.org/10.1186/s12302-014-0012-7>
64. Wang, W., Ndungu, A. W., Li, Z., Wang, J. (2017). Microplastics pollution in inland freshwaters of China: A case study in urban surface waters of Wuhan, China. *Science of The Total Environment*, 575. <https://doi.org/10.1016/j.scitotenv.2016.09.213>
65. Waryati, Rahayu, D. E., Putri, R. H. W. P. (2023). The effect of frequency of use and washing of gallons on the abundance of microplastics in DAMIU treated water. *Konferensi Nasional Teknik Sipil*

- Ke-17*, 9, 16–17.
66. Yanuar, A. T., Pramudia, Z., Dwi Susanti, Y. A., Kurniawan, A. (2024). Analysis of microplastics in spring water. *Emerging Contaminants*, 10(1), 100277. <https://doi.org/10.1016/j.emcon.2023.100277>
67. Zhang, M., Li, J., Ding, H., Ding, J., Jiang, F., Ding, N. X., Sun, C. (2020). Distribution characteristics and influencing factors of microplastics in urban tap water and water sources in Qingdao, China. *Analytical Letters*, 53(8), 1312–1327. <https://doi.org/10.1080/00032719.2019.1705476>
68. Zhang, N., Li, Y. Bin, He, H. R., Zhang, J. F., Ma, G. S. (2021). You are what you eat: Microplastics in the feces of young men living in Beijing. *Science of the Total Environment*, 767, 144345. <https://doi.org/10.1016/j.scitotenv.2020.144345>
69. Zhang, Q., Xu, E. G., Li, J., Chen, Q., Ma, L., Zeng, E. Y., Shi, H. (2020). A review of microplastics in table salt, drinking water, and air: Direct human exposure. *Environmental Science and Technology*, 54(7), 3740–3751. <https://doi.org/10.1021/acs.est.9b04535>